



- ① TREATED - 4 X 4 - 16' IN LENGTH
- ② #4 BARE COPPER GROUND WIRE - STAPLED LENGTH OF POLE CONNECTED TO GROUND ROD.
- ③ MINIMUM OF 60 AMP SERVICE PANEL WITH METER SOCKET AND RAIN TIGHT DISCONNECT.
- ④ GROUND ROD & CLAMP.
- ⑤ 2X4 BRACES

CONSTRUCTION TEMPORARY SERVICE POLE		APPROVED BY:	
SCALE: NONE			
DATE: 1998		DRAWN BY: JRS	
		REVISED:	
ARAB ELECTRIC CO-OP INC.		DRAWING NUMBER	SKETCH # 1